CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245719

Address: 2230 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Piers/Caissons Inspection - Mitchell Schwarz Failed Friday, March 14, 2025

Residential

Corrective Action Required:

2 Misc Plans do not specify pier size.

(2) piers

1 16"x36" pier E most pier 1 20"x36" pier W most pier.

Comments: