

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244549  
Address: 1535 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Not Ready	Friday, March 14, 2025

Corrective Action Required:

1	Misc	Pay fees -Final grade and sod -pending driveway inspection -splash blocks and sump pump discharge to extend 36" from foundation -all outlets in unfinished spaces must be gfci protected or single receptacle outlet (see garage) -water meter to be 14"-18" from top of meter to well ring lid
---	------	--

**Comments:**