

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243955  
Address: 3141 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Partial	Friday, March 14, 2025

Informational:

1 Misc

3-14-25 Dustin A, DW is formed and compacted. Aggregate is not deep enough along curb and there is bare dirt showing. Must have min 3 inch of aggregate. Fail  
3-14-25 Dustin A, DW recalled in. It has been dug out where aggregate is deep enough. Approved to pour

**Comments:**