

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235207
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Friday, March 14, 2025

Corrective Action Required:

1	LOWER LEVEL	Pre-rock behind tub/shower-Firecaulk penetrations
---	-------------	---

Corrective Action Required:

2	FIRST FLOOR	Pre-rock behind tub/shower-Firecaulk penetrations
---	-------------	---

Corrective Action Required:

3	SECOND FLOOR	
---	--------------	--

Corrective Action Required:

4	THIRD FLOOR	
---	-------------	--

Corrective Action Required:

5	STAIR TOWER 1	**THIS IS NORTH STAIR A**
---	---------------	----------------------------------

Lower floor:

-stair side 2nd layer

1st floor:

-stair side 2nd layer

2nd floor:

-stair side 2nd layer

Corrective Action Required:

6	STAIR TOWER 2	**THIS IS SOUTH STAIR A**
---	---------------	----------------------------------

Lower floor:
-stair side 2nd layer

1st floor:
-stair side 2nd layer

2nd floor:
-stair side 2nd layer

Corrective Action Required:

7 STAIR TOWER 3

****THIS IS REAR STAIR B****

Corrective Action Required:

8 ELEVATOR 1

Comments: