



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20115933, Building Permit - Commercial  
Address: 1196 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Passed	Wednesday, December 14, 2011

**Comments: OK TO COVER WHEN READY AFTER ABANDONED CONDENSATE  
EXHAUST DUCT AND L.V. CABLE ARE REMOVED.**