

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245719
Address: 2230 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Monday, March 17, 2025

Informational:
1 Misc 3-14-25 Dustin A, Dw will need to be recalled in .Weather coming in and they are not pouring today
3-17-25 Dustin A, Dw is formed and compacted. Approved to pour. Informed builder that expansion joints are needed along approach and against storm and curb. Approved to pour

Comments: