

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|--------------|----------|------------------------|
| Rated Assembly Inspection | Khanh Nguyen | Failed | Monday, March 17, 2025 |

Corrective Action Required:

| | | |
|---|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | 2-hr fire barrier: -guest suite side and stairwell side-2nd layer -wall inside lower level bathroom and storage space under guest rm-2nd layer -2 hr floor assembly under guest suite Elevator shaft wall: -interior side-side and back walls only -outer side-basement floor front wall **Elevator fire barrier enclosure: outer side screw pattern was not inspected **Provide visual access to verify fire-caulking of plumbing penetration behind laundry wall; 2-hr protection around roof drainage above guest suite bathroom |
|---|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Comments: