## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20245553

Address: 3211 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Monday, March 17,

Residential 2025

Corrective Action Required:

1 Misc Fire blocking material must be of approved materials

-fireblock wall space to ceiling space at rear garage wall

-fire block hvac chase to ceiling space in pantry

-provide protection for dryer vent at top plate penetration

-fire block foyer walls into garage furr down

-fireblock garage stud space into stairs landing joist space(seal gaps)

-deck not constructed at time of inspection

Comments: