CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105

Address: 800 NW WARD RD, Unit:IR, LEES SUMMIT, MO 64086800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Robb Popp Failed Monday, March 17,

Commercial 2025

Informational:

1 Misc 3/17/25

**Partial inspection only:

-Segments A,B,C and D approved for occupancy

Corrective Action Required:

2 Misc **Partial inspection of segments A,B,C and D only

-Complete corrections for all other departments

-Missing landings at doors to courtyard (doors to remain inaccessible to

public until courtyard is complete)

-Adjacent exterior courtyard, door landings and pool equipment room will be

inspected at later date.

-Paint exterior metallic gas lines

Comments: