

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244922  
Address: 3205 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Partial	Monday, March 17, 2025

Corrective Action Required:

1	Misc	3-17-25 Dustin A, Dw is framed and and compacted. There is standing water in approach and it will need to be removed and recompactd. Will need called back in for another inspection 3-17-25 Dustin A, water has been removed. and recompactd. Approved to pour
---	------	--

**Comments:**