

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244549
Address: 1535 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Tuesday, March 18, 2025

Corrective Action Required:

1	Misc	Pay fees -Final grade and sod -pending driveway inspection -splash blocks and sump pump discharge to extend 36" from foundation -water meter to be 14"-18" from top of meter to well ring lid
---	------	---

Comments: