

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242381
Address: 2213 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Failed	Tuesday, March 18, 2025

Corrective Action Required:

1	Miscellaneous Correction	3/18/25 Maintain storm inlet and perimeter protection -Remove silt and debris from inlet, replace damaged, worn gutter buddy and install with cinder blocks separating filter from inlet -Complete erosion control methods at perimeter
---	-----------------------------	---

Comments: