

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232899
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Stabilized Subgrade	Bobby Richest	Partial	Tuesday, November 19, 2024

Informational:

1	Misc	11-14-24 BR Contractor installed 9" subgrade aggregate base on Shenandoah Dr..
		11-19-24 BR Contractor installed 9" subgrade aggregate base on Lindberg Ln., Golden Ln., 5th Terr., 6th St., Highland Park Dr., wood Ln.
		3-18-25 BR Contractor (selby excavation) is recompacting aggregate base on Shenandoah Dr., Lindberg Ln., Golden Ln., 5th Ter., 6th St., Highland Park Dr., SE Wood Ln., SE Lincoln St.,

Comments: