

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242859

Address: 1432 SW WINTHROP TER, LEES SUMMIT, MO 64081
1430 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|--------------|----------|---------------------------|
| Electrical Service Inspection | Khanh Nguyen | Failed | Wednesday, March 19, 2025 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Shall bond the 1430 service disconnect enclosure -Tape the EGC with green tape at 1432 sub-panel -The grounding clamps at rebar do not have tight connections. |
|---|------|---|

Comments: