



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115575, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Wednesday, December 14, 2011

Comments: ENGINEER LETTER RECEIVED DATED DEC. 9, 2011 ALLOWING USE OF #1 ALUMINUM SERVICE FEEDER CONDUCTORS IN LIEU OF #3 COPPER. RELEASE SERVICE.