

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242859

Address: 1432 SW WINTHROP TER, LEES SUMMIT, MO 64081
1430 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Failed	Wednesday, March 19, 2025

Corrective Action Required:

1 Misc

Attic wall:

- Fire caulk membrane penetration at ridge and above master bathroom/bed wall
- Nail upper edge of wall on 1430 side

Comments: