



## **FIRE DEPARTMENT**

**Prevention Division  
(816)969-1300**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20244755	Date:	March 19, 2025
Project Title:	FLEX SPACES LEE'S SUMMIT - BUILDING B	Applicant:	
Location:	60 SE THOMPSON DR, Unit:B, LEES SUMMIT, MO 64082	ALLIANCE PETROLEUM LLC	
Type of Work:		4251 LINDELL BLVD	
Occupancy Group:	F-1	ST LOUIS, MO 63108	
Description:	NORTH BUILDING B- FLEX SPACE -	Primary:	
	NEW BUILDING WITH SPACES TO RENT FOR		
	CONTRACTOR GARAGES		
Construction Type:	Type IIB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Craig Hill**

**Rejected**

1. Action Required: Move fire department connection to the west side of the building
2. Action Required: FDC needs to be a 4" storz connection with a 30-degree elbow.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**