

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243960
Address: 840 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|------------|----------|--------------------------|
| Above Ceiling Inspection | Robb Popp | Failed | Thursday, March 20, 2025 |

| Informational: | |
|----------------|---|
| 1 | Miscellaneous |
| | Correction |
| | Hard lids and soffits ok to cover |
| | -Complete all MEPs, support electrical and lights, expose all J boxes |

Comments: