CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20245059Address:2743 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Devon Perry	Failed	Thursday, March 20, 2025
Informational: 1 Misc	3-19-25 DP. DW is being poured tomorrow. Contractor is calling this back in due to incoming rain/snow.		
	3-20-25 DP. Contractor needs to remove water and recompact aggregate before pouring.		

Comments: