

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243123

Address: 3719 SW KNOXVILLE CT, LEES SUMMIT, MO 640823717 SW KNOXVILLE CT, LEES SUMMIT, MO  
64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Thursday, March 20, 2025

Corrective Action Required:

1 Misc

Unit 3717 only:

- Sidewalk and driveway not approved
- Final grade, sod, gutters, downspout, and sump pump extension
- Provide sewer tracer wire port at grade
- Label address on outside power disconnect
- No landing for deck landing

**Comments:**