

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20235733  
Address: 209 SE GREEN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Robb Popp	Partial	Thursday, March 20, 2025

Informational:

1          Misc

- Conduit from mech room 118 to west exterior
- Communication conduit from 118 to line 5 (108 mechanical)
- Conduit for (4) receptacles at SW corner of City Hall
- Conduit from SE sidewalk to NE corner and East to courtyard stairs and clocktower
- Christmas tree run at SE corner of city hall to quayside box roughly 15' from west side of building
- Ground ring with (3) ground rods at transformer location for service disconnect
- West side wicket inspection passed and is okay to cover
- East side wickets and ballard lighting
- East wicket, Ballard and holiday lighting
- Electrical street lighting conduit west side of Johnson street south of Cooper
- East side of Green street tree planters
- Corner of Green and 3rd conduit for (7) light poles and (5) tree receptacles
- South side of 3rd street (3) tree boxes and (3) light poles
- North side of 3rd street complete from Green to Johnson St
- South side of 3rd street complete from Green to Johnson St
- West side of ATT conduit for (6) light poles to the trash enclosure
- West side light poles and wickets conduit near city hall, boxes. Next to all 5 wickets boxes not completed

Informational:

2

Misc

- North East side lighting and wicket conduit in front of plaza area.

**Comments:**