

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245749
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, March 21, 2025

Corrective Action Required:

1	Misc	-Inspection denied due to erosion control. Re-establish erosion control to compliance. Flattened front wattle needs to be replaced. Silt fence along the side and rear-especially around the storm inlet-shall be installed to compliance -Shall submit footing inspection report before scheduling an inspection
---	------	--

Comments: