

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245198  
Address: 2012 NE BLUESTONE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, March 21, 2025

Corrective Action Required:

1	Misc	-Module cannot be located outside bedroom window **Need Fire approval for this
		-Label panel per plan **Use the sticker label printer for the AC ratings

**Comments:**