

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243960
Address: 840 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Friday, March 21, 2025

Informational:

1	Miscellaneous Correction	Hard lids and soffits ok to cover -Remove temp lighting, install cover plate at associated J box -Remove extra whip and install knockout cover at kitchen -Install cover at low volt J box at kitchen **OK for tile everywhere not listed above. Leave tile out for inspection items
---	-----------------------------	--

Comments: