

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243955
Address: 3141 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Friday, March 21, 2025

Informational:

1	Misc	3-14-25 Dustin A, DW is formed and compacted. Aggregate is not deep enough along curb and there is bare dirt showing. Must have min 3 inch of aggregate. Fail 3-14-25 Dustin A, DW recalled in. It has been dug out where aggregate is deep enough. Approved to pour 3-21-25 Dustin A, Dw has been poured to city specs. Pass
---	------	---

Comments: