

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Shawn Hoffman	Partial	Monday, March 24, 2025

Corrective Action Required:

1	Misc	- Light pole bases at North edge of building, East-West 5 towards parking area Conduits not installed - 4 Light pole bases North East corner of lot Conduit not ran (ok to pour)
---	------	--

Comments: