

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20245549  
Address: 1933 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Monday, March 24, 2025

Informational:

1	Miscellaneous Correction	Garage PFH and front porch truss tie downs passed and are okay to cover
---	--------------------------	---

This is a partial pass only

Corrective Action Required:

3	Misc	- Tighten anchor bolt at return wall between garage doors
		- Missing TJC37 hangers at garage trusses
		- Minimum of three studs required at exterior corners ( basement West side both corners)
		- Nail off siding at sill plate back of house

**Comments:**