

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244922
Address: 3205 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Monday, March 24, 2025

Corrective Action Required:

1	Misc	3-17-25 Dustin A, Dw is framed and and compacted. There is standing water in approach and it will need to be removed and recompactd. Will need called back in for another inspection 3-17-25 Dustin A, water has been removed. and recompactd. Approved to pour 3-24-25 Dustin A, Dw has been poured to city specs. Pass
---	------	--

Comments: