

BC Engineers, Inc.

5720 Reeder • Shawnee, KS 66203 • (913)262-1772

December 9, 2011


City of Lee's Summit Codes Administration
P.O. Box 1600
Lee's Summit, Missouri 64063

Re: Tip Top Tux Summit Fair


The electrical contractor installed #1 aluminum conductors in lieu of #3 copper conductors for the service feeder from the service gutter to the 277/480 volt panel in the tenant space. All other conductors are copper on this project. This is acceptable.

Should you have any questions or require discussion about any of these comments, please contact myself as you require.

Respectfully,



Robert W. Curry, PE



File: PACOM20115575