



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20112915, Building Permit - Commercial
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Friday, December 16, 2011

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING AND IN-WALL
SYSTEMS AT SPACES: 74; 75; 76; 77; 78; 78B; 79; 79B; 80; 81; 82
S,E,W; 95 N WALL FROM 73 TO WEST; 98 W WALL; 162 N; 71; 72;
83; 84; 85; 155 SW CORNER;

Comments: