

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

| | | | |
|--------------------|--|---------------------------|-------------------|
| Permit No: | PRCOM20115575 | Date: | December 16, 2011 |
| Project Title: | TIP TOP TUX | Applicant: | |
| Location: | 880 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086 | National Fire Suppression | |
| Type of Work: | Sprinkler Alteration | 501 Sunshine Road | |
| Occupancy Group: | M | Kansas City, KS 66115 | |
| Description: | TENANT FINISH FOR TUX | (913) 321-9208 | |
| RENTAL | | | |
| Construction Type: | Type IIB (Unprotected) | | |
| Map Page: | 195A | | |

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans recieved December 8, 2011. The correct address is 880 NW Blue Pkwy, Suite E.

2. 2006 IFC 510.1- Identification. Fire protection equipment shall be identified in an approved manner. Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements shall be identified for the use of the fire department. Approved signs required to identify fire protection equipment and equipment location, shall be constructed of durable materials, permanently installed and readily visible.

Valves shall be clearly marked to indicate thae area served.

3. Confirm adequate coverage to the wall in the space to the right (east ?).

4. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule tests and inspection.

