

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244023
Address: 2748 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Tuesday, March 25, 2025

Corrective Action Required:

1	Misc	-Sidewalk inspecion pending - complete final grading and sod - Sump discharge to be 36" away from foundation - Provide splash pads - Uncover water meter pit and set to grade with - meter 14-18" below lid - Land sewer trace wire at grade
---	------	---

Comments: