

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245409  
Address: 1616 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Tuesday, March 25, 2025

Corrective Action Required:

2	Misc	-final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -install gutters -land sewer tracer wire in box -address deck post to beam connection deck post over notched. Provide approved deck post to be connector
---	------	--

**Comments:**