

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244021
Address: 1113 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Devon Perry	Passed	Tuesday, March 25, 2025

Informational:
1 Misc 2-28-25 DP. DW was formed, aggregate compacted, told to keep cross slopes in compliance throughout the approach for the width of the sw. Approved to pour.

3-25-25 DW was poured, forms removed, cross slopes in compliance. Passed

Comments: