CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20244575Address:2721 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, March 25, 2025

Corrective Action Required:

Correc	live Action Requir	red:
1	Misc	 Driveway and sidewalk inspection pending
		- Provide Final grading and sod
		 sump discharge to be 36" away from foundation Provide splash
		- Provide splash pads
		- Land sew trace wire at grade
		 Provide security screws at exterior doors

Comments: