

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240929
Address: 2319 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Mitchell Schwarz	Failed	Tuesday, March 25, 2025

Corrective Action Required:	
1	DCM3 ESC REQUIRED 2 DAY
	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. REPAIR DOWNED SILT FENCE CLEAN MUD FROM STOM INLETS AT REAR OF LOT AND RE-ESTABLISH EROSION CONTROL AT REAR OF LOT

Comments: