

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20235732

Address: 1901 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640641921 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640642001 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640642021 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640642031 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640642 NE ALURA WAY, LEES SUMMIT, MO 640641900 NE DISCOVERY AVE, LEES SUMMIT, MO 640641920 NE DISCOVERY AVE, LEES SUMMIT, MO 640641901 NE DISCOVERY AVE, LEES SUMMIT, MO 640641921 NE DISCOVERY AVE, LEES SUMMIT, MO 64064100 NE ALURA WAY, LEES SUMMIT, MO 64064200 NE ALURA WAY, LEES SUMMIT, MO 64064251 NE ALURA WAY, LEES SUMMIT, MO 64064250 NE ALURA WAY, LEES SUMMIT, MO 64064221 NE ALURA WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection</b>	Devon Perry	Partial	Wednesday, March 26, 2025

Informational:

1 Misc

9-30-24 DP. Now that roads are in we will need to add erosion control around the private areas. We will need silt fence around unvegetated areas, also the throats of the storm boxes will need gutter buddies. All gutter buddies will need 2 cinder blocks behind them.

10-14-24 DP. Still needing to address erosion control around private roads and storm structures.

11-12-24 DP. ESC is in good working order.

11-19-24 DP. ESC is in good working order

3-26-25 DP. ESC is in good working order

**Comments:**