

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Wednesday, March 26, 2025

Corrective Action Required:

1	STAIR TOWER 1	complete
---	---------------	----------

Corrective Action Required:

2	STAIR TOWER 2	complete
---	---------------	----------

Corrective Action Required:

3	STAIR TOWER 3	complete
---	---------------	----------

Corrective Action Required:

4	FIRST FLOOR	Building F Complete except as noted: 157-NOT READY 389-Walls only ok-complete meps at ceiling and seal dead space
---	-------------	--

Building G:
complete

Building H:
complete

Building J:
complete

Corrective Action Required:

5	SECOND FLOOR	Building F:
---	--------------	-------------

-Units and corridor complete

Building G:

-Units and corridor complete

Building H:

Units and corridor complete

Building J:

complete

Corrective Action Required:

6 THIRD FLOOR

*Building F

-Units and corridor approved

Building G:

-Units and corridor approved

Building H:

-Units and corridor approved

Building J:

-Units and corridor approved

Corrective Action Required:

7 FOURTH FLOOR

*Building F

Complete

*Building G:

complete

Building H:

Complete

Building J:

Complete

Corrective Action Required:

8 ELEVATOR 1

Interior framing ok all floors

Corrective Action Required:

9 ELEVATOR 2

Elevator in G:

Framing approved

Corrective Action Required:

10 LOWER LEVEL

H, I, J approved

-Exterior garage light metal boxes-all bonded

Comments: