CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234376 Address: 600 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Wednesday, March 26, 2025
Corrective Action Required:			
1 Misc	Not ready for inspection.		
	-Protect #6 GEC to rods. Cover grounding connections to rods -Provide 2/0 copper grounding electrode conductors to water and building steel. Use the building steel to interconnect all the other grounding electrodes -Provide 2/0 copper main bonding jumper from disconnect to gutter		

Comments: