



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20115933, Building Permit - Commercial  
Address: 1196 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Alarm Test</b>	Joe Dir	Passed	Monday, December 19, 2011
<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Monday, December 19, 2011
<b>Final Building Inspection - Commercial</b>	Mark Harding	Failed	Monday, December 19, 2011

Corrective Action Required  
4 MISC

1. REAR RESTROOM SINK MAX HEIGHT 34"

**Comments:**