

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231204  
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:   | Outcome: | Date:                     |
|---------------------------------|--------------|----------|---------------------------|
| <b>Above Ceiling Inspection</b> | Khanh Nguyen | Partial  | Wednesday, March 26, 2025 |

Corrective Action Required:

|   |      |                                                          |
|---|------|----------------------------------------------------------|
| 1 | Misc | Upper floor-complete                                     |
|   |      | Above basement restrooms-fire caulk ceiling around edges |

**Comments:**