

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244575
Address: 2721 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Thursday, March 27, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Driveway and sidewalk inspection pending- Provide Final grading and sod- sump discharge to be 36" away from foundation Provide splash- Provide splash pads- Land sew trace wire at grade- Provide security screws at exterior doors
---	------	--

Comments: