

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244348
Address: 2317 SW MORRIS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|----------------|----------|--------------------------|
| Sidewalk Inspection | Dustin Agcopra | Failed | Thursday, March 27, 2025 |

Informational:
1 Misc 03-20-25 Jamie S, SW gravel is compacted, and slopes are within city standards. I did make them move a porta-john off of a storm box before inspection. Approved to pour.

Comments: