

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105

Address: 800 NW WARD RD, Unit:IR, LEES SUMMIT, MO 64086800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Thursday, March 27, 2025

Corrective Action Required:

1 Misc

Pre final for segment E:
4th Floor-

1456-Laundry outlet not working
1452-Remove sprinkler head protection above mechanical
1450-Correct escutcheon above mechanical, open J box in bedroom
1447-Adjust door to self close and latch
Sprinkler room-Install signage in corridor, sprinkler head covered with drywall mud
Handrails at stairs to have min 1.5" clearance at stair E
Fix smoke seals at fire door to D

Comments: