

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243878  
Address: 1543 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Wednesday, February 26, 2025

Corrective Action Required:

1	Misc	TCO EXPIRED NOTICE OF VIOLATION SENT. Mitchell Schwarz 02/13/2025 3:11 PM
		-provide as graded plot plan -sod -splash blocks and sump pump discharge to extend 36" from foundation -uncover coved water meter for inspection

**Comments:**