CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20245981Address:2532 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Inspection - Residential	Khanh Nguyen	Failed	Friday, March 28, 2025
Corrective Action Required:			

Corrective Action Required:

 1
 Misc
 -Complete fencing around pool and gate(s)

 -Secure all LFNC raceways within 12" of enclosure

Comments: