

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244024
Address: 3203 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Friday, March 28, 2025

Informational:

1	Misc	3-13-25 Dustin A, Part of sw is poured, forms still on. One section has not been poured and ada ramp needs replaced. 3-27-25 Dustin A, ADA ramp is formed and compacted. Approved to pour Note. Due to the angle of the road and a shallow gas line could not get the turnaround and the notification pad complianct at the same time. Chose to do the turn around in compliance. .
---	------	---

Comments: