

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243667  
Address: 2610 SW TRACKER LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Passed	Friday, March 28, 2025

Corrective Action Required:

1	Misc	12-9-24 Dustin A, Dw was called in but gravel was to shallow. They are going to correct and i will be back my tomorrow.
		12-10-24 Dustin A, DW has been corrected, Approved to pour.
		3-28-25 Dustin A, dw has been poured to city specs. Passed.

**Comments:**