

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20241886
Address: 251 NE ALURA WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Friday, March 28, 2025

Informational:

1 Misc

Exterior footing:

- Spread footing from AC/7 to AC/1.1 to J/1 to J/5
- Rest of footing, except at vehicle entrance from A/17 to D/18

Interior footing:

- Spread footing from AC/2 to A/1.1
- Elevator pad and step footing
- Col footing D/2-7, B/3-6, and A/3-6;

Foundation wall:

- From J/1.5 to A/17; AC/2 to A/1.1; elevator area

Comments: