

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234376
Address: 600 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Friday, March 28, 2025

Corrective Action Required:

1	Misc	-Service disconnect grounding electrode conductor to rod must be copper -Verify that the grounding clamp to rebar is compatible with aluminum conductor
---	------	------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: